



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned by Government of Karnataka Undertaking)

Telephone No. 080-22252128,

E-Mail gmqs.work@gmail.com, gmqs@bescom.co.in

No: BESCOM/GM(QS&S)/DGM-3/AE/BC-11/24-25/ **CYS-31**

Encl:

O/o GM (QS&S)

Corporate Office,

K.R. Circle, Bangalore-560 001

Date: **14 MAY 2024**

OFFICIAL MEMORANDUM

Sub : Vendor approval for supply of LT/HT Line Hardware Materials & Structural Materials by M/s VD Blueberry Pvt Ltd, Bangalore.

Ref : 1. Firms letter dtd: 14.03.2024 & 19.04.2024.
2. Approved by Director (Technical), BESCOM vide para (20)/259 dated: 07.05.2024 of T.O note no: BESCOM/ GM(QS&S)/DGM-3/AE/BC-11/24-25/342 dated: 07.05.2024

Approval is hereby accorded to the below mention firm as approved vendor to BESCOM for supply of the material to prospective consumers in BESCOM area for Electrification of layouts, M.S. Buildings, Action plan works, Self-execution works, Turnkey works & Partial Turnkey works etc.

Sl. No	Name of the Firm/ Address/Contact details	Equipment/Materials	Period of validity upto
1	M/s VD Blueberry Pvt Ltd., Registered Office: No.G005, Ground Floor, Blue Bell Apartment, Hosakote Hosur Road, Hoskote, Bangalore - 562114 Factory Unit: Plot No. SPL-R-3, KSSIDC Industrial Estate, Chokkahalli, hosakote, Bengaluru-562114 Ph No: 9845004586/9845388223 E-mail: blueberry@blueberryinc.in/ blueberry.incorpo@gmail.com	SPMT Materials for erection of transformer on 25/63kVA on 9mtr RCC/PSCC pole	13.05.2025
2		Single Pole Mounted Transformer Kit for erection of Transformers on 11Mtr Spun Poles	
3		Double Pole TC sets for erection of transformers of 25/63/100kVA & 100/300kVA on RCC/PSCC 9Mtr pole	
4		11kV DP set	
5		11kV Horizontal cross arm	
6		LT & HT Single Top support	
7		Earth Guard Stirrup	
8		PG clamps	
9		11kV Danger Board	
10		2 Pin & 4 Pin cross Arm	
11		Clamps for PSCC/RCC poles	
12		11kV Special 3 Pin Cross Arms	
13		Spiral Earth Electrode	
14		Spacers for DTC wiring	
15		Copper Lugs	
16		G I Grounding Pipe B-class, 42mm Dia, 2.5mtrs long, 3.2mm thick with bolts & nuts, GI strip & washers complete	
17		Guy set (Insulator & GI wire has to be purchased by BESCOM approved Vendors)	
18		Fish plate	

The approval is subject to the following conditions:-

1. The prospective consumers who purchases above said material shall stand guarantee for the materials for a period of Five years from the date of commissioning.

2. The vendor shall furnish all the relevant valid type test reports as per BESCOM Technical specification & its amendment from time to time and reports shall not be older than 05 years issued by M/s CPRI/ERDA or any Govt. lab/Govt. Testing houses only and Vendor approvals are considered based on type test reports.
3. All the components utilized for manufacturing above products has to be same as that of utilized in the type test sample.
4. GTP and Drawing approvals shall be obtained by the firm before offering for inspections.
5. The above materials shall be manufactured as per approved drawings (Please refer www.bescom.karnataka.gov.in for BESCOM approved drawings) and GTP & drawing approvals shall be obtained before suppliers are made.
6. The above materials shall be got inspected by QS&S Engineers, BESCOM before they are put into service.
7. BESCOM reserves the right to call for any document/credentials for verification during drawing approvals/inspection of material/equipment by BESCOM authorities to ascertain the manufacturing experience/performance/technical suitability of the material. Further BESCOM reserves the right to withdraw/cancel the vendor approval issued, in case of any violation of the approved drawing and specification at any time, poor quality /defective materials/equipment to BESCOM projects, poor performance, poor after sales service, etc.
8. The approval communicated does not in any manner reduce or dilute the responsibility & liabilities of the manufacturer, nor does not absolve or abridge the rights of the owner. The liabilities of the manufacturer for any loss or damage suffered by the owner consequent to approval of incorrect drawings are obsolete.
Irrespective of any approval conveyed, the materials supplied shall be 100% suitable for the purpose for which it is intended for use and in case of any changes required, the supplier shall replace the materials or modify at the site with free of cost based on the approvals.
9. Wherever applicable the type test certificate/BIS license should be renewed prior to the expiry date.
10. The application for renewal of vendor approval proposal shall be submitted before 3 months from the expiry of the vendor approval O.M or otherwise shall be treated as new application.

Approved by Director (Technical)

Shree 14/5/24
(S.T. Shanthamallappa)
General Manager (El.)
Quality Standards and Safety,
BESCOM.

Copy to-

1. The Chief General Manager, Operations/CA/Projects, BESCOM, Bangalore.
2. All the Chief Engineer (Electy.,) O&M Zones, BESCOM.
3. The General Manager (El.) Procurement / DAS, BESCOM.
4. All Superintending Engineers (El.), O&M Circle, BESCOM.
5. All Executive Engineers (Ele.) O&M Divisions, BESCOM.
6. PS to D (T) to place it before Director (Technical), BESCOM.
7. M/s VD Blueberry Pvt Ltd., Registered Office: No.G005, Ground Floor, Blue Bell Apartment, Hosakote Hosur Road, Hoskote, Bangalore – 562114
Factory Unit: #152/2 Deepa Arcade, K Mallasandra, Hosakote – Hosur Road, Hoskote Taluk, Bengaluru – 560067
8. Office copy / M.F.